

List of Designated Connection Points

Accessible Installed Capacity (MW_{AC}) specified in below table are maximum allowable limit.

Sr. No.	The name of Substation/Power Station at the Connection	Location Region/State	To be connected bus-bar (kV)	Accessible installed Capacity (MW_{AC})
1	Chauk Substation	Chauk Township, Magway Region 20°52'00.00"N 94°49'25.00"E	66	40
2	Taungdwingyi Substation	Taungdwingyi Township, Magway Region 19°59'45.00"N 95°31'20.00"E	66	40
3	Ta Nyaung Substation	Salin Township, Minbu District, Magway Region 20°51'01.75"N 94°41'29.49"E	66	40
4	Buddhakone Substation	Pakokku Town, Magway Region 21°21'25.00"N 95°05'39.00"E	66	40
5	Chaungku Substation	Pauk Township, Magway Region 21°31'15.00"N 94°24'58"E	66	40

Sr. No.	The name of Substation/Power Station at the Connection	Location Region/State	To be connected bus-bar (kV)	Accessible installed Capacity (MW_{AC})
6	Kyungchaung Power Plant	Magway Region 21°11'15.60"N 94°48'10.68"E	66	40
7	Belin Substation	Kyaukse Town, Mandalay Region N 21.669918 E 96.153763	33	30
8	Letpanhla Substation	Singu Township, Pyinoolwin District, Mandalay Region 22°33'16.47"N 96° 3'8.61"E	33	30
9	Myingyan Substation	Myingyan Township, Mandalay Region 21°25'57.00"N 95°23'33.00"E	33	30
10	Tharzi Substation	Tharzi Township, Mandalay Region 20°51'33.8"N 96°03'21.04"E	33	30
11	Thapyaywa Substation	Tharzi Township, Mandalay Region 20°59'25.00"N 95°58'29.00"E	33	30
12	Taungoo Substation	Oaktwin Township, Bago Region 18°54'13.00"N 96°26'40.00"E	33	30

Sr. No.	The name of Substation/Power Station at the Connection	Location Region/State	To be connected bus-bar (kV)	Accessible installed Capacity (MW_{AC})
13	Tharyargone Substation	Kyaukdagar Township, Bago Region 18°05'22.50"N 96°38'10.50"E	33	30
14	Thephyu Substation	Yaytarshay Township, Bago Region 19°25'31.90"N 96°15'57.40"E	33	30
15	Kamarnat Substation	Bago Township, Bago Region 17°20'10.70"N 96°31'05.40"E	66	40
16	Minhla Substation	Minhla Township, Tharyarwadi District, Bago Region 17°59'51.20"N 95°43'52.70"E	33	30
17	Oakshitpin Substation	Padaung Township, Bago Region N 18.669076 E 94.996618	66	40
18	Shwedaung Power Plant	Pyay Township, Bago Region 18°43'37.37"N 95°13'44.55"E	66	40

Sr. No.	The name of Substation/Power Station at the Connection	Location Region/State	To be connected bus-bar (kV)	Accessible installed Capacity (MW_{AC})
19	Aungchanthar Substation	Monywa Township, Sagaing Region 22°09'00.80"N 95°06'38.00"E	33	30
20	Ngapyawdine Substation	Kanbalu Township, Sagaing Region 23°04'03.02"N 95°44'29.45"E	33	30
21	Nyaungpingyi Substation	Salingyi Township, Sagaing Region 22°06'16.00"N 95°06'12.00"E	33	30
22	Ohntaw Substation	Sagaing Town, Sagaing Region 21°57'02.00"N 95°52'38.00"E	66	40
23	Wartaya Substation	Shwepyithar Township, Yangon Region 16°59'56.75"N 96°03'17.35"E	33	30
24	Nay Pyi Taw (1) Substation	Nay Pyi Taw 19°47'43.00"N 96°04'53.00"E	33	30

Sr. No.	The name of Substation/Power Station at the Connection	Location Region/State	To be connected bus-bar (kV)	Accessible installed Capacity (MW_{AC})
25	Nay Pyi Taw (2) Substation	Ottarathiri Township, Nay Pyi Taw 19°47'19.60"N 96°04'12.90"E	66	50
26	Shwemyo Substation	Tatkon Township, Nay Pyi Taw 20°00'13.71"N 96°15'17.44"E	33	30
27	Pathein Substation	Kangyidaunt Township, Ayeyarwaddy Region 16°51'33.00"N 96°50'46.70"E	66	40
28	Kyaiklat Substation	Kyaiklat Town, Ayeyarwaddy Region 16°28'03.10"N 95°42'19.80"E	66	40
29	Athoke Substation	Yaykyi Township, Ayeyarwaddy Region 17°11'04.30"N 95°05'24.10"E	66	40
30	Myanaung Power Plant	Ayeyarwaddy Region 18°16'24.44"N 95°18'28.43"E	66	40
			Total MW	1,060